

# RAFTER J IMPROVEMENT AND SERVICE DISTRICT

## Application for Water Connection Permit

Date: \_\_\_\_\_

For Lot: \_\_\_\_\_

Owner: \_\_\_\_\_

Service Line tap size at the water main: \_\_\_\_\_

Water Meter size (connection fee basis\*): \_\_\_\_\_

Commercial Lots Fire Protection:

Yes \_\_\_\_\_ No \_\_\_\_\_ Size of Line \_\_\_\_\_

All Connection Fees will be paid with application submittal to the **Rafter J Improvement and Service District.**

\*Connection Fees.....

\*\* Water meter shall be remotely readable by radio. Preferred manufacturer is Metron-Farnier. Please contact the Rafter J Office for more information.

Please note the fee doesn't include the cost of a water meter or any installation materials.

| Water Meter Size** | Fee    |
|--------------------|--------|
| ¾ inch             | \$ 500 |
| 1 inch             | 1,000  |
| 1 ½ inch           | 2,500  |
| 2 inch             | 5,000  |
| 3 inch             | 10,000 |
| 4 inch             | 18,000 |
| 6 inch             | 40,000 |

Please see information regarding the service conditions on the back of the form.

# **SERVICE CONDITIONS**

Revised 11-19-2010

- (1) Water users must also pay for the actual labor, material, and equipment costs required to make the tap and to repair roads and landscaping damaged by the installation of the water service.
- (2) All taps and service lines must be inspected by the Rafter J Improvement and Service District prior to backfilling and placing in service.
- (3) It is recommended but not mandatory that all water service lines be equipped with backflow preventers conforming to Wyoming Department of Environmental Quality Standards.
- (4) All water users must comply with any and all water use rules or restrictions that may be issued by the Rafter J Improvement and Service District.
- (5) All taps exceeding ¾" in diameter must be approved by the Rafter J Improvement and Service District Board of Directors. The District reserves the right to refuse water taps or services exceeding ¾" in diameter.
- (6) All water services regardless of size shall be equipped with water meters properly sized for the actual water use, at user expense.
- (7) Water meters shall conform to Rafter J Improvement and Service District Standards.
- (8) Rafter J Improvement and Service District shall have the right to access the water user's property to record the meter readings and to inspect the service line.
- (9) In addition to the base service rate, metered water usage in excess of 5,000 gallons per month will be charged at \$0.75 per 1,000 gallons, or such other rate as may be determined from time to time by the Rafter J Improvement and Service District Board.
- (10) All water service line leaks shall be promptly repaired by the water user.
- (11) The water user shall notify the Rafter J Office of any water line leaks, as well as proposed repairs in advance of those repairs.
- (12) Water users desiring to increase the size of their water tap shall be charged the difference in the tap fee price between the increased tap size and their existing tap size.