

ANNUAL DRINKING WATER QUALITY REPORT FOR RAFTER J. IMP. & SER. DISTRICT, PWS # 5600822C, 2014

Is my water safe?

We are pleased to present this year's Annual Water Quality Report (Consumer Confidence Report) as required by the Safe Drinking Water Act (SDWA). This report is designed to provide details about where your water comes from, what it contains, and how it compares to standards set by regulatory agencies. This report is a snapshot of last year's water quality. We are committed to providing you with information because informed customers are our best allies.

Do I need to take special precautions?

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/ Centers for Disease Control (CDC) guidelines on appropriate means to lessen the risk of infection by Cryptosporidium and other microbial contaminants are available from the Safe Water Drinking Hotline (800-426-4791).

Where does my water come from?

The water comes from three ground water wells

Source water assessment and its availability

no source water assessment

Why are there contaminants in my drinking water?

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's (EPA) Safe Drinking Water Hotline (800-426-4791).

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity:

microbial contaminants, such as viruses and bacteria, that may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife; inorganic contaminants, such as salts and metals, which can be naturally occurring or result from urban stormwater runoff, industrial, or domestic wastewater discharges, oil and gas production, mining, or farming; pesticides and herbicides, which may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses; organic Chemical Contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff, and septic systems; and radioactive contaminants, which can be naturally occurring or be the result of oil and gas production and mining activities. In order to ensure that tap water is safe to drink, EPA prescribes regulations that limit the amount of certain contaminants in water provided by public water systems. Food and Drug Administration (FDA) regulations establish limits for contaminants in bottled water which must provide the same protection for public health.

How can I get involved?

If there are any questions, contact the operator for answers.

Monitoring and reporting of compliance data violations

Additional Information for Lead

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Rafter J. Imp. and Service District is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>.

Water Quality Data Table

In order to ensure that tap water is safe to drink, EPA prescribes regulations which limit the amount of contaminants in water provided by public water systems. The table below lists all of the drinking water contaminants that we detected during the calendar year of this report. Although many more contaminants were tested, only those substances listed below were found in your water. All sources of drinking water contain some naturally occurring contaminants. At low levels, these substances are generally not harmful in our drinking water. Removing all contaminants would be extremely expensive, and in most cases, would not provide increased protection of public health. A few naturally occurring minerals may actually improve the taste of drinking water and have nutritional value at low levels. Unless otherwise noted, the data presented in this table is from testing done in the calendar year of the report. The EPA or the State requires us to monitor for certain contaminants less than once per year because the concentrations of these contaminants do not vary significantly from year to year, or the system is not considered vulnerable to this type of contamination. As such, some of our data, though representative, may be more than one year old. In this table you will find terms and abbreviations that might not be familiar to you. To help you better understand these terms, we have provided the definitions below the table.

Contaminants	MCLG or MRDLG	MCL, TT, or MRDL	Your Water	Range Low High		Sample Date	Violation	Typical Source
	Inorganic Contaminants							
Fluoride (ppm)	4	4	0.2	NA		2013	No	Erosion of natural deposits; Water additive which promotes strong teeth; Discharge from fertilizer and aluminum factories
Nitrate[measured as Nitrogen] (ppm)	10	10	.3	NA		2014	No	Runoff from fertilizer use; Leaching from septic tanks, sewage; Erosion of natural deposits
Copper- source Water (ppm)		1.3	.12	NA		2014	No	Corrosion of household plumbing systems; Erosion of natural deposits
Microbiological Contaminants								
Total Coliform (positive samples/month)	0	1	0	NA		2014	No	Naturally present in the environment
Radioactive Contaminants								
Alpha emitters (pCi/L)	0	15	4.4	NA		2013	No	Erosion of natural deposits

Undetected Contaminants

The following contaminants were monitored for, but not detected, in your water.

	MCLG	MCL	Your		
	or	or	Your		
<u>Contaminants</u>	<u>MRDLG</u>	<u>MRDL</u>	<u>Water</u>	<u>Violation</u>	<u>Typical Source</u>
Antimony (ppb)	6	6	ND	No	Discharge from petroleum refineries; fire retardants; ceramics; electronics; solder; test addition.
Arsenic (ppb)	0	10	ND	No	Erosion of natural deposits; Runoff from orchards; Runoff from glass and electronics production wastes
Barium (ppm)	2	2	ND	No	Discharge of drilling wastes; Discharge from metal refineries; Erosion of natural deposits
Beryllium (ppb)	4	4	ND	No	Discharge from metal refineries and coal-burning factories; Discharge from electrical, aerospace, and defense industries
Cadmium (ppb)	5	5	ND	No	Corrosion of galvanized pipes; Erosion of natural deposits; Discharge from metal refineries; runoff from waste batteries and paints
Chromium (ppb)	100	100	ND	No	Discharge from steel and pulp mills; Erosion of natural deposits
Copper - source water (ppm)		1.3		No	Corrosion of household plumbing systems; Erosion of natural deposits
Cyanide [as Free Cn] (ppb)	200	200	ND	No	Discharge from plastic and fertilizer factories; Discharge from steel/metal factories
Lead - source water (ppb)		15	ND	No	Corrosion of household plumbing systems; Erosion of natural deposits
Mercury [Inorganic] (ppb)	2	2	ND	No	Erosion of natural deposits; Discharge from refineries and factories; Runoff from landfills; Runoff from cropland
Nitrite [measured as Nitrogen] (ppm)	1	1		No	Runoff from fertilizer use; Leaching from septic tanks, sewage; Erosion of natural deposits
Selenium (ppb)	50	50	ND	No	Discharge from petroleum and metal refineries; Erosion of natural deposits; Discharge from mines
Thallium (ppb)	0.5	2	ND	No	Discharge from electronics, glass, and Leaching from ore-processing sites; drug factories
2,4-D (ppb)	70	70	ND	No	Runoff from herbicide used on row crops

2,4,5-TP (Silvex) (ppb)	50	50	ND	No	Residue of banned herbicide		
Alachlor (ppb)	MNR	MNR	ND	No			
Atrazine (ppb)	3	3	ND	No	Runoff from herbicide used on row crops		
Benzo(a)pyrene (ppt)	0	200	ND	No	Leaching from linings of water storage tanks and distribution lines		
Carbofuran (ppb)	40	40	ND	No	Leaching of soil fumigant used on rice and alfalfa		
Dalapon (ppb)	200	200	ND	No	Runoff from herbicide used on rights of way		
Di (2-ethylhexyl) adipate (ppb)	400	400	ND	No	Discharge from chemical factories		
Di (2-ethylhexyl) phthalate (ppb)	0	6	ND	No	Discharge from rubber and chemical factories		
Dibromochloropropane (DBCP) (ppt)	0	200	ND	No	Runoff/leaching from soil fumigant used on soybeans, cotton, pineapples, and orchards		
Dinoseb (ppb)	7	7	ND	No	Runoff from herbicide used on soybeans and vegetables		
Endrin (ppb)	2	2	ND	No	Residue of banned insecticide		
Heptachlor (ppt)	0	400	ND	No	Residue of banned pesticide		
Heptachlor epoxide (ppt)	0	200	ND	No	Breakdown of heptachlor		
Hexachlorobenzene (ppb)	0	1	ND	No	Discharge from metal refineries and agricultural chemical factories		
Hexachlorocyclopentadiene (ppb)	50	50	ND	No	Discharge from chemical factories		
Lindane (ppt)	200	200	ND	No	Runoff/leaching from insecticide used on cattle, lumber, gardens		
Methoxychlor (ppb)	40	40	ND	No	Runoff/leaching from insecticide used on fruits, vegetables, alfalfa, livestock		
Oxamyl [Vydate] (ppb)	200	200	ND	No	Runoff/leaching from insecticide used on apples, potatoes and tomatoes		
PCBs [Polychlorinated biphenyls] (ppt)	0	500	ND	No	Runoff from landfills; Discharge of waste chemicals		
Pentachlorophenol (ppb)	0	1	ND	No	Discharge from wood preserving factories		
Picloram (ppb)	500	500	ND	No	Herbicide runoff		
Simazine (ppb)	4	4	ND	No	Herbicide runoff		
Toxaphene (ppb)	0	3	ND	No	Runoff/leaching from insecticide used on cotton and cattle		
Benzene (ppb)	0	5	ND	No	Discharge from factories; Leaching from gas storage tanks and landfills		
Carbon Tetrachloride (ppb)	0	5	ND	No	Discharge from chemical plants and other industrial activities		

Chlorobenzene (monochlorobenzene) (ppb)	100	100	ND	No	Discharge from chemical and agricultural chemical factories
o-Dichlorobenzene (ppb)	600	600	ND	No	Discharge from industrial chemical factories
p-Dichlorobenzene (ppb)	75	75	ND	No	Discharge from industrial chemical factories
1,2-Dichloroethane (ppb)	0	5	ND	No	Discharge from industrial chemical factories
1,1-Dichloroethylene (ppb)	7	7	ND	No	Discharge from industrial chemical factories
cis-1,2-Dichloroethylene (ppb)	70	70	ND	No	Discharge from industrial chemical factories
trans-1,2-Dichloroethylene (ppb)	100	100	ND	No	Discharge from industrial chemical factories
Dichloromethane (ppb)	0	5	ND	No	Discharge from pharmaceutical and chemical factories
1,2-Dichloropropane (ppb)	0	5	ND	No	Discharge from industrial chemical factories
Ethylbenzene (ppb)	700	700	ND	No	Discharge from petroleum refineries
Styrene (ppb)	100	100	ND	No	Discharge from rubber and plastic factories; Leaching from landfills
Tetrachloroethylene (ppb)	0	5	ND	No	Discharge from factories and dry cleaners
1,2,4-Trichlorobenzene (ppb)	70	70	ND	No	Discharge from textile-finishing factories
1,1,1-Trichloroethane (ppb)	200	200	ND	No	Discharge from metal degreasing sites and other factories
1,1,2-Trichloroethane (ppb)	3	5	ND	No	Discharge from industrial chemical factories
Trichloroethylene (ppb)	0	5	ND	No	Discharge from metal degreasing sites and other factories
TTHMs [Total Trihalomethanes] (ppb)	NA	80	ND	No	By-product of drinking water disinfection
Toluene (ppm)	1	1	ND	No	Discharge from petroleum factories
Vinyl Chloride (ppb)	0	2	ND	No	Leaching from PVC piping; Discharge from plastics factories
Xylenes (ppm)	10	10	ND	No	Discharge from petroleum factories; Discharge from chemical factories

Unit Descriptions					
Term			Definition		
ppm			ppm: parts per million, or milligrams per liter (mg/L)		

ppb	ppb: parts per billion, or micrograms per liter ($\mu\text{g/L}$)
ppt	ppt: parts per trillion, or nanograms per liter
pCi/L	pCi/L: picocuries per liter (a measure of radioactivity)
positive samples/month	positive samples/month: Number of samples taken monthly that were found to be positive
NA	NA: not applicable
ND	ND: Not detected
NR	NR: Monitoring not required, but recommended.
Important Drinking Water Definitions	
Term	Definition
MCLG	MCLG: Maximum Contaminant Level Goal: The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.
MCL	MCL: Maximum Contaminant Level: The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.
TT	TT: Treatment Technique: A required process intended to reduce the level of a contaminant in drinking water.
AL	AL: Action Level: The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.
Variances and Exemptions	Variances and Exemptions: State or EPA permission not to meet an MCL or a treatment technique under certain conditions.
MRDLG	MRDLG: Maximum residual disinfection level goal. The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.
MRDL	MRDL: Maximum residual disinfectant level. The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.
MNR	MNR: Monitored Not Regulated
MPL	MPL: State Assigned Maximum Permissible Level
For more information please contact:	

Contact Name: Dave Stichel

Address:

P.O. BOX 3123

Alpine, WY 83128

Phone: 307-880-0427

Fax: 307-654-7680

E-Mail: dstichel8@gmail.com